


## Overview of Testing Results for Lead in Drinking Water and Corrective Actions for NAVAL STATION GUANTANAMO BAY, CUBA OUTDOOR PLAY AREAS

The Navy is committed to maintaining safe drinking water on its installations. City water supplied to the Navy and the Navy's water distribution system is regularly tested and in compliance with the Safe Drinking Water Act. Because lead exposure is a particular concern for children, and lead may be added to drinking water through the pipes, fittings, solder, and fixtures inside a building, the EPA recommends, but does not mandate, that we test the lead content of drinking water in priority areas such as youth centers (YCs), child development group homes (CDGHs) and child development centers (CDCs).

Navy environmental personnel conducted lead testing at the Outdoor Play Areas on Naval Station Guantanamo Bay in accordance with Navy and EPA guidelines. Samples from various locations on the installation were sent to a state-certified laboratory for analysis.

At the Naval Station Guantanamo Bay Outdoor Play Areas, six (6) outlets used for drinking were tested. Out of the six (6) samples collected, zero (0) water outlets tested above the EPA recommended level for lead in drinking water in schools and childcare centers of 20 parts per billion (ppb). One part per billion is equal to one drop of water in an Olympic-size swimming pool.



A copy of all test results is enclosed for your information. The test results are presented in two tables: Table 1 **Summary of Results** summarizes the data by category of use (e.g., drinking, cooking, washing). Table 2 **Summary Statistics** summarizes all the data.

**Table 1** provides a description of each sampling location using three columns; *Category*, *Sampling ID*, and *Outlet Description*. The *Category* column gives information about whether the outlet is used for drinking water (water fountain), cooking (food preparation), or washing (primarily hand-washing). The *Sample ID* column is the identification used to label each sample bottle. The *Outlet Description* column contains additional information to describe the outlet sampled under each category.

EPA sampling protocol requires water to not be used for between 8 and 18 hours prior to first draw sampling. Therefore, *Initial Sampling Results* were from first draw samples collected early in the morning before any water was used. The *Initial Sampling Results* also indicate whether resampling is required and the date that fixtures greater than 20 ppb were secured.

To learn more about lead in drinking water schools and day care centers visit this EPA website at: [http://water.epa.gov/drink/info/lead/schools\\_index.cfm](http://water.epa.gov/drink/info/lead/schools_index.cfm).

Navy Water Quality Reports:

[http://www.cnmc.navy.mil/regions/cnrse/om/environmental\\_support/water\\_quality\\_information.html](http://www.cnmc.navy.mil/regions/cnrse/om/environmental_support/water_quality_information.html)

To answer any questions you may have on the sampling program, contact the Naval Station Guantanamo Bay Public Affairs Officer at 011-5399-4502. If you have any health questions or concerns, you are encouraged to call the Naval Hospital at 011-5399-72360 . On island, use the five-digit number.